

CTQC

检验报告

J I A N Y A N B A O G A O



国家变压器质量监督检验中心

CTQC



检测
CNAS L0681



(2006)国认监认字(080)号



2006000394Z



机检电(2004)07号

CERTIFICATION OF REPORT

No: CTQC/B-08.405

Manufacturer: HANGZHOU QIANTANG RIVER ELECTRIC GROUP CO., LTD.
(HANGZHOU QIANDIAN SPECIAL TRANSFORMER CO., LTD.)

Test object name: Dry-type power transformer

Test object type: SC10-20000/35

Serial: 081458001

Test items: Routine tests, type tests, measurement of sound levels, short-circuit withstand test, partial discharge measurement.

Standards: GB1094.11, GB/T10228-1997, GB/T1094.10-2003, contract requirements.

Results: The test results of routine tests, type tests, measurement of sound levels, short-circuit withstand test, partial discharge measurement of SC10-20000/35 are in accordance with standards and technical contract requirements. The sample passed the above tests.

Date: Dec.09.2008

Period of validity 5 years

Approved: Chen kui



**China National Transformer Quality Supervision
Testing Center**

